

OWENS CORNING ROOFING AND ASPHALT, LLC

ONE OWENS CORNING PARKWAY
TOLEDO, OHIO 43659
419.248.5500 FAX 419.325.0500
Voicemail: 800.733.1551 ID#5500
Email: mel.sancrant@owenscorning.com

Mel Sancrant



August 10, 2011

Re: ESP Low E Reflective Underlayment and Owens Corning Shingles

This letter is to confirm that it is acceptable to Install ESP low E Reflective Therma Sheet Underlayment. The use of this underlayment product can be used as an alternative to #15 asphalt saturated felt with Owens Corning shingles. Application of the underlayment must be installed in accordance with ESP Low E Reflective Therma Sheet underlayment application instructions.

When used on slopes 2:12 to under 4:12 this product must have overlapped seams of 26 inches on each course.

Owens Corning does not accept responsibility for the performance of any product not manufactured by Owens Corning. Please keep in mind Owens Corning's Warranty cover manufacturing defects in the shingles only, we do not cover workmanship. If you have any further questions please give me a call.

Sincerely,

A handwritten signature in cursive script that reads "Mel Sancrant".

Mel Sancrant
Roofing Specialist
Building Science & Technology